IDAHO ROCKY MOUNTAIN RANCH PWS# 7190028 SOURCE WATER ASSESSMENT FINAL REPORT

November 28, 2000



State of Idaho Department of Environmental Quality

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

11/28/00

Under the Federal Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the Act. The Idaho Department of Environmental Quality is completing the assessments for all Idaho public drinking water systems. The assessment for your particular drinking water source is based on a land use inventory within a 1,000 foot radius of your drinking water source, sensitivity factors associated with the source and characteristics associated with either your aquifer or watershed in which you live.

This report, *Source Water Assessment for Public Water System* # 7190028 describes the public drinking water system, the associated potential contaminant sources located within a 1,000` boundary around the drinking water source, and the susceptibility (risk) that may be associated with any associated potential contaminants. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this system. The results should <u>not be</u> used as an absolute measure of risk and is not intended to undermine the confidence in your water system.

The Idaho Rocky Mountain Ranch drinking water system consists of one well located outside the one hundred-year flood plain, which is rated moderately susceptible to potential contaminants. This final *moderate* rating falls in all category scores. The following considerations were applied in determining your final well rating: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. Based on Custer County's geology your well is located in a well-drained area, where the soil composition is such that the downward movement of contaminants is low. Custer County is classified as a low farm chemical use area, in which influence from such type of agricultural chemicals upon your water system is also low. A copy of the susceptibility analysis for your system along with a map showing any potential contaminant sources is included with this summary. Information regarding the potential contaminants within the 1,000' boundary have been summarized and included in Table 1 below.

Table 1.

SITE#	Source Description	Source of Information	Potential Contaminants
1	No Potential Contaminants	Database Search	
	Identified		

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a "pristine" area or an area with numerous industrial and/or agricultural land uses, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.


11/28/00

For Idaho Rocky Mountain Ranch, source water protection activities should focus on implementation of practices aimed at protecting the well from contaminants that may leach within the designated source water area. You may want to establish a dialog with the following state and local agencies related to the leachable contaminants that may affect the well. Source water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term.

For assistance in developing source water protection strategies please contact the Idaho Falls Regional Office (IDEQ) office at (208) 528-2650.

11/28/00

Idaho Rocky Mountain Ranch: Well #1 PWS Number: 7190028



- Weilhead
- **Enhanced Inventory**
- **Business Mailing List**
- **CERCLIS Site**
- Dairy
- Non Dairy CAFO
- Injection Well
- Mineral Extraction Site
- NPDES Site
- RICRIS Site
- SARA Title III Site (EPCRA)
- Toxic Release Inventory
- Closed UST Site
- Open UST Site
- **LUST Site**
- Landfill
- Wastewater Land App. Site

Zone 1B - 1000' Fixed Radi

Note: Refer to Preliminary Contaminant Inventory Form for identification of the Potential Contaminant Source(s)



Restriction of Liability: Neither the State of Ideho nor the Ideho Department of Health and Welfare, Division of Environmental Lepaumeirs or ries to and trestate, burnout or consortimental Casility, not employees make any warranty, sople as or implied, or secure any legal facility or responsibility for the accuracy, completeness or usefulness of any information or data provided. Metadela is provided for all data sets, and no data should. be used without first reading and understanding its limitations. The dat could include technical inaccuracies or hypographical errors.

The Division of Environmental Quality may update, modify, or revise the data used at any time, without notice

POTENTIAL CONTAMINANT INVENTORY LIST OF ACRONYMS AND DEFINITIONS

<u>AST (Aboveground Storage Tanks)</u> – Sites with aboveground storage tanks.

<u>Business Mailing List</u> – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

<u>CERCLIS</u> – This includes sites considered for listing under the <u>Comprehensive Environmental Response Compensation</u> and <u>Liability Act (CERCLA)</u>. CERCLA, more commonly known as ASuperfund≅ is designed to clean up hazardous waste sites that are on the national priority list (NPL).

<u>Cyanide Site</u> – DEQ permitted and known historical sites/facilities using cyanide.

<u>Dairy</u> – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

<u>Deep Injection Well</u> – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (IDEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100year floodplains.

<u>Group 1 Sites</u> – These are sites that show elevated levels of contaminants and are not within the priority one areas.

<u>Inorganic Priority Area</u> – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

<u>Landfill</u> – Areas of open and closed municipal and non-municipal landfills.

<u>LUST (Leaking Underground Storage Tank)</u> – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

<u>Mines and Quarries</u> – Mines and quarries permitted through the Idaho Department of Lands.)

<u>Nitrate Priority Area</u> – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

NPDES (National Pollutant Discharge Elimination System) – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

<u>Organic Priority Areas</u> – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

<u>Recharge Point</u> – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RICRIS – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

<u>UST (Underground Storage Tank)</u> – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

<u>Wastewater Land Applications Sites</u> – These are areas where the land application of municipal or industrial wastewater is permitted by IDEQ.

<u>Wellheads</u> – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.

11/28/00 5

Ground Water Susceptibility Report

Public Water System Number 7190028 IDAHO ROCKY MOUNTAIN RANCH

Final Wall Kanking	11	Moderate	Moderate	Moderate	Moderate
Final Susceptibility Source Score		tt	Ιτ	π.	75
Cumulative Potential Contaminant / Land Use Score		0	0	0	z
	ontaminant Source / Land Use Score - Zone	0	. 0	0	0
is there irrigated agricultural lands that occupy > 50% of	ON	0	0	0	
Sources of Class II or III leacheable contaminants or	ON	0	0	0	
Contaminant Source Present	ои	0	0	ō	
Potential Contaminant / Land Use - 2008 III	·				
Potential Conta	ontaminant Source / Land Use Score - Zone	0	0	0	0
II ənoZ əcu band		0	0	0	
Sources of Chasa II or III leacheable contaminants or	ОИ	0	0	0	
Contaminant Sources Present	ON	ő	Ö	ŏ	
Pocencial Concaminant / Land Use - 2004 II					
Tocal Isidnedol Isdon	Contaminant Source / Land Use Score - Zon	0	0	0	z
al enos esu basi	Less Than 25% Agricultural Land	0	0	0	0
Zone lB contains or intercepts a Group 1 Area	Tour Then Set Person Lucal Land	0	0	0	2
mumixem edulog b	UUA	ñ	ő	ő	v
Sources of Class II or III leacheable contaminants or	ON	ŏ	ŏ	Ö	
(Score = 1 Sources X 2) 8 Points Maximum		0	0	Ö	0
Contaminant sources present (Number of Sources)	ON	0	0	0	0
Potential Contaminant / Land Use - 204E 1B					
Total Potential C	1 Contaminant Source/Land Use Score - Zon	0	0	0	0
IOC, VOC, SOC, or Microbial sources in Zone IA	ON	ON	ON	ON	ON
Farm chemical use high	ON	0	0	0	
Af and seu band	RANGELAND, WOODLAND, BASALT	0	О .	0	0
AI 3NOS - seu band \ Land Use Contaminant () Potential Contaminant		Score	Score	Score	erong
		100			
	Totologic S	9			
Aquitard present with > 50 teet cumulative thickness	ON	z			
	ON	t			
Depth to first water > 300 feet					
Vadose composed of gravel, fractured rock or unknown Depth to first water > 300 feet	AES NO	Į			
Soils are poorly to moderately drained Vadose zone composed of gravel, fractured rock or unknown Depth to litat water > 300 feet	NO AES	t			
Vadose composed of gravel, fractured rock or unknown Depth to first water > 300 feet	ON	z 			
Hydrologic Sensitivity Soils are poorly to moderately drained Vadose zone composed of gravel, fractured rock or unknown Depth to first water > 300 feet		z 			
Well located outside the 100 year flood plain Hydrologic Sensitivity Soils are poorly to moderately drained Soils are poorly to moderately drained Vadose zone composed of gravel, fractured rock or unknown Dapth to first water > 300 feet	NO Total Syatem Construction S	z 			
Highest production 100 feet below static water level Well located outside the 100 year flood plain Fracelogic Sensitivity Soils are poorly to moderately drained Soils are poorly to moderately drained Vadose zone composed of gravel, fractured rock or unknown Dapth to first water > 300 feet	NO Total System Construction 5 NO	z 			
Casing and annular seal excend to low permeability unit Highest production 100 feet below static water level Well located outside the 100 year flood plain in Hydrologic Sensitivity Soils are poorly to moderately drained Soils are poorly to moderately drained Soils are poorly to moderately drained to Manage Soils are poorly to moderately drained to Manage Soils are Depth to first water > 300 feet Depth to first water > 300 feet	NO NO Total System Construction 5 NO	z 			
Mellhead and auriace seal maintained Casing and annular seal extend to low permeability unit Highest production 100 feet below static water level Well located outside the 100 year flood plain Hydrologic Sensitivity Soils are poorly to moderately drained Soils are poorly to moderately drained Vadose zone composed of gravel, fractured rock or unknown Dapth to first water > 300 feet	NO TOEST SYSTEM CONSTRUCTION S NO NO NO NO NO NO NO NO NO N	z 			
Well meets IDWR construction standards Wellhead and surface seal maintained Casing and annular seal extend to low permeability unit Highest production 100 feet below static water level Well located outside the 100 year flood plain Soils are poorly to moderately drained Soils are poorly to moderately drained Vadose tone composed of gravel, fractured fock or unknown Dapth to first water > 300 feet	NO Total System Construction S NO NO YES NO NO NO NO NO NO NO NO NO N	7 			
Sanicary Survey (if yes, indicate date of last survey) Well meets IDWR construction standards Casing and annular seal extend to low permeability unit Highest production 100 feet below static water level Highest production 100 feet below static water level Well located outside the 100 year flood plain Soils are poorly to moderately drained Soils are poorly to moderately drained Vadose tone composed of gravel, fractured rock or unknown Dapth to first water > 300 feet	NO Total System Construction 5 NO	z 			
Well meets IDWR construction standards Wellhead and surface seal maintained Casing and annular seal extend to low permeability unit Highest production 100 feet below static water level Well located outside the 100 year flood plain Soils are poorly to moderately drained Soils are poorly to moderately drained Vadose tone composed of gravel, fractured fock or unknown Dapth to first water > 300 feet	NO Total System Construction S NO NO YES NO NO NO NO NO NO NO NO NO N	7 			
Driller Log Available Sanicary Survey (if yes, indicate date of last survey) Well meets IDWR construction standards Casing and annular seal extend to low permeability unit Highest production 100 feet below static water level Mell located outside the 100 year flood plain Soils are poorly to moderately drained Soils are poorly to moderately drained Soils are poorly to moderately drained	NO Total System Construction 5 NO	7 			